



# AGO BIG

INSTALLATION TYPE:  
WALL-MOUNTED

LED



IP20



025.566 (REV01)

MADE IN ITALY

4100E  
4100F  
4100G

C.V.  
[V]

LED  
2W 110-277V

IP 20

**NO!**

| *Art. |                |        |
|-------|----------------|--------|
| 4100E | 3.74" x 7.28"  | 2.559" |
| 4100F | 3.74" x 11.22" | 2.559" |
| 4100G | 3.74" x 15.35" | 2.559" |

**2**

= 0.49"  
= 0.98"

**1**

Terminal block is not included. For the installation qualified personnel may be required. (we recommend MAMMUT/ FORBOX 0.00233 in")

**4**

**5**

**7**

**8**

**9**

[sales@gordonbullard.com](mailto:sales@gordonbullard.com)  
[www.byiba.com](http://www.byiba.com)  
1 877-964-4646



991 South Gull Lake Dr.  
Richland, MI 49083  
USA



## IMPORTANT

To ensure equipment safety you must carefully follow the instructions below. This leaflet must be kept handy by personnel entrusted with all ordinary and extraordinary maintenance.

- Before any installation or maintenance operation on the bulb, make sure it is disconnected from power
- Fit the correct bulbs, according to the type and power indicated on the lamp data label.
- Make sure the lamp technical features are compatible with the use you are going to make of it.
- Should you have any doubt, refer to the dealer or ask an electrician.
- When connecting to the mains, follow the correct colour code for power cables: (N) blue, (L) brown or black and, only for class I equipment, (T) yellow/green.
- When lamps are to be fitted to the wall directly through their ceramic parts, fasten the fixing screws lightly, to avoid breaking the ceramic.
- To clean the lamp on the outside, use a soft cloth, possibly wet. Do not use solvents or abrasive products. No liquid must get in contact with the lamp interior parts.
- Do not touch the equipment with dirty hands.



= Class I equipment, must be connected to an earth terminal.



= Double insulated lamp, does not need earthing.



= Electrical equipment in class III, electrical safety guaranteed by low voltage tension, does not require grounding



= Minimum distance to be observed from all lit up objects.



= Replace immediately the safety glass, if damaged, with the original part.



= The lamp uses low pressure bulbs, and needs no protection glass.



= The equipment at the end of its life must be collected separately from other waste.